## **City of Fayetteville Staff Review Form**

2022-0542

Legistar File ID

7/5/2022

City Council Meeting Date - Agenda Item Only N/A for Non-Agenda Item

Tim Nyander		6/15/2022	VASTEWATER TREATMENT (730)			
Submitted By		Submitted Date	Division	Division / Department		
	Actio	n Recommendation:				
Staff recommends approval of the r Center of Springdale, Inc. in the am						
		Budget Impact:				
5400.730.5800-541	5400.730.5800-5414.00		Water and Sewer			
Account Number		<del></del>	Fund			
02069.1		Plant Pumps and Equipment - WWTP				
Project Number		<u> </u>	Project Title			
Budgeted Item?	Yes	Current Budget	\$	1,459,141.00		
		Funds Obligated	\$	948,991.13		
	•	Current Balance	\$	510,149.87		
Does item have a cost?	Yes	Item Cost	\$	42,632.83		
Budget Adjustment Attached?	No	Budget Adjustment	\$	-		
·		Remaining Budget	\$	467,517.04		
Purchase Order Number:		Previous Ordinand	ce or Resolution	V20210527		
Change Order Number:		Approval Date:				

**Comments:** Freight is included in the quoted price. Taxes are estimated at \$3,787.43 for a total cost of \$42,632.83.

**Original Contract Number:** 



### CITY COUNCIL MEMO

#### **MEETING OF JULY 5, 2022**

TO: Mayor and City Council

**THRU:** Susan Norton, Chief of Staff

Water & Sewer Committee

FROM: Tim Nyander, Utilities Director

**DATE:** June 15, 2022

SUBJECT: Electric Motor Center – Pump Repair for Gregg Avenue Sewer Lift Station

#### **RECOMMENDATION:**

Staff recommends approval of the repair of a pump at the Gregg Avenue sewer lift station from Electric Motor Center of Springdale, Inc. in the amount of \$38,845.40 plus applicable taxes.

#### **BACKGROUND:**

The Gregg Avenue Lift Station uses four submersible KSB pumps to pass sewage through the collection system. It feeds directly into Hamestring Lift Station which delivers over 85% of the West Side's average 7+ MGD of wastewater influent.

### **DISCUSSION:**

In late March, the Jacobs maintenance team received an overload alarm from pump no. 1. Upon arriving to troubleshoot, the on-call worker discovered the main seal had failed. The pump was pulled and sent to Electric Motor Center for a hidden-damages inspection. With pump no.1 out of commission, this lift station is down to 2 working pumps. This is of concern because this lift station has recently experienced overflows during high flow events.

Staff has received a repair quote from Electric Motor Center in the amount of \$38,845.40 plus applicable taxes. Freight charges are not applicable because the pump can be picked up at the vendor's location in Springdale after the repair is complete.

Because it was necessary to have the repair facility disassemble the units to determine the extent of hidden and unknown damage to equipment already purchased, a bid waiver and/or formal sealed bidding is not necessary according to Ark. Code Ann. §19-11-203(14)(DD).

# **BUDGET/STAFF IMPACT:**

Funds are available in the Upgrade/Replace Lift Stations – WWTP account within the Water and Sewer fund.

## **Attachments:**

Quote from Electric Motor Center

804 N. JEFFERSON SPRINGDALE, AR 72764 PHONE; (479)756-8040  FAX; (479)756-0567 EMAIL rayatemc@gmail.com  NUMBER OF PAGES:  SUBJECT;	
THOMBER OF THE STATE OF THE STA	
TO; Michael, Josh FROM; Ray	
80 H.P. KSB KRTK 250-401/606 X	(a
Revise Allbrac + Seals + o'pings	é
New impeller, New stationary wear Rin and machine went.	59
\$38,845.40 8 WKS ON INFE	//

Thanks, Ray