City of Fayetteville Staff Review Form

2022-0778

Legistar File ID

9/6/2022

City Council Meeting Date - Agenda Item Only N/A for Non-Agenda Item

Tim Nyander		8/18/2022 W	WASTEWATER TREATMENT (730)		
Submitted By		Submitted Date	Submitted Date Division /		
	Acti	on Recommendation:			
Staff recommends approving the West Side Water Resource Recovapplicable taxes.					
		Budget Impact:			
5400.730.5800-5801.00		Wa	Water and Sewer		
Account Number			Fund		
02032.1		WWTP Bu	WWTP Building Improvements		
Project Number			Project Title		
Budgeted Item	? Yes	Current Budget	\$	4,139,028.00	
		Funds Obligated	\$	1,172,662.87	
		Current Balance	\$	2,966,365.13	
Does item have a cost	? Yes	Item Cost	\$	45,710.88	
Budget Adjustment Attached	? No	Budget Adjustment	\$	-	
		Remaining Budget	\$	2,920,654.25	
Purchase Order Number:		Previous Ordinance	Previous Ordinance or Resolution #		
Change Order Number:		Approval Date:			

Comments: Taxes are estimated at \$4,060.88 for an estimated total cost of \$45,710.88.

Original Contract Number:



CITY COUNCIL MEMO

MEETING OF SEPTEMBER 6, 2022

TO: Mayor and City Council

THRU: Susan Norton, Chief of Staff

Water & Sewer Committee

FROM: Tim Nyander, Utilities Director

DATE: August 18, 2022

SUBJECT: Elite Building Solutions – HVAC Unit Replacements at West Side WRRF

RECOMMENDATION:

Staff recommends approving the replacement of two HVAC units in the Motor Control Center (MCC) building at the West Side Water Resource Recovery Facility from Elite Building Solutions in the amount of \$41,650.00 plus applicable taxes.

BACKGROUND:

The West Side Water Resource Recovery Facility has two HVAC units in the MCC building. This building contains all of the control units for the process equipment at the treatment facility. The two HVAC units are currently not working.

DISCUSSION:

Staff is looking to replace both HVAC units at the West Side treatment facility. Both units are original to the facility and have reached their user life. The cost to fix each unit isn't justifiable for their age. The existing units are 15 years old and they cool both electrical rooms for our biological basins process at West Side. In each building, there is sensitive equipment that must stay between 50-85 degrees to operate correctly or this equipment will fault out causing process equipment to shut down at the treatment facility.

Elite Building Solutions has provided a quote for the two HVAC unit replacements in the amount of \$41,650.00. There are two options for the units, coated coils and uncoated coils. This building does not have a corrosive environment and only contains electrical equipment, so staff would prefer to go with the uncoated coils to save money since the coating is not necessary.

Staff recommends approval of the replacement of the two HVAC units from Elite Building Solutions in the amount of \$41,650.00 plus taxes to maintain a temperature controlled environment for electrical equipment at the West Side treatment facility. The City has a contract with Elite Building Solutions via Resolution 265-21, which is attached.

BUDGET/STAFF IMPACT:

Funds are available in the WWTP Building Improvements account.

Attachments:

Quote from Elite Building Solutions Resolution 265-21



Elite Building Solutions
446 North 40th St.
Springdale, AR 72762
HVACR License # 2428360

Office: 479-770-5566 Fax: 479-927-1881

Date: August 16, 2022

City of Fayetteville
113 W. Mountain Street
Fayetteville, AR 72701

Reference: HVAC 15 S. Broyles Street

Quote Number: TPQ202280

To whom it may concern,

Elite Building Solutions is pleased to provide service to supply materials and labor to replace two 10-ton split systems at the listed location. Equipment Scope – 2 – 10-ton Heat Pump Split Systems, Sub-Base Kit for Floor Mounting, 2" filter rack, Discharge Plenum and Grille Kit, Return Air Grille Kit, NO STRIP HEAT, Single Circuit/dual compressor, Thermostat, Hail Guards, 1-year parts and labor warranty. Equipment cost with coated coils \$48,187.50. Estimated labor \$3,600.00. Line sets and miscellaneous \$800.00. Total job cost \$52,587.50. Lead time is 24 weeks. Equipment cost without coated coils \$37,250.00. Estimated labor \$3,600.00. Line sets and miscellaneous \$800.00. Total job cost \$41,650.00. Lead time 20 weeks. Price excludes all applicable taxes, electrical work, plumbing work, and coring. Work to be performed during normal business hours. Prices firm for (30) days. Please allow 7-10 days, upon approval for logistics.

Regards, Tony Price

Elite Building Solutions

Cell: 479-287-8285 Fax: 479-927-1881 Office: 479-770-5566 Execution by Authorized Representatives: SUBMITTED BY: Tony Price DATE: August 16, 2022 CUSTOMER ACCEPTANCE: **EBS APPROVAL** City of Fayetteville Customer Acceptance (typed/printed name) EBS Approval (typed/printed name) Title ------Title -----Customer Acceptance (signature) EBS Approval (signature) Date Date



113 West Mountain Street Fayetteville, AR 72701 (479) 575-8323

Resolution: 265-21

File Number: 2021-0772

BID #21-36 ARACREBS II, LLC D/B/A ELITE BUILDING SOLUTIONS:

A RESOLUTION TO AWARD BID #21-36 AND AUTHORIZE A ONE YEAR CONTRACT WITH ARACREBS II, LLC D/B/A ELITE BUILDING SOLUTIONS FOR HVAC SERVICES ON AN ON-CALL BASIS WITH AUTOMATIC RENEWALS FOR UP TO FOUR ADDITIONAL YEARS

BE IT RESOLVED BY THE CITY COUNCIL OF THE CITY OF FAYETTEVILLE, ARKANSAS:

Section 1: That the City Council of the City of Fayetteville, Arkansas hereby authorizes awards Bid #21-36 and authorizes a contract with Aracrebs II, LLC d/b/a Elite Building Solutions for HVAC services on an on-call basis for a period of one year with automatic renewals for up to four additional years.

PASSED and APPROVED on 11/2/2021

Approved:

Lioneld Jordan, Mayor

Attest:

Kara Paxton, City Clerk Treasurer